

PUBLIC NOTICE

Monitoring/Reporting Violation

Failure to Submit a Disinfectant Level Quarterly Report (DLQOR)

MONITORING, ROUTINE (DBP), MAJOR/CHLORINE

The HIGHPORT MARINA water system PWS ID 0910130 has violated the monitoring/reporting requirements set by Texas Commission on Environmental Quality (TCEQ) in Title 30, Texas Administrative Code (30 TAC), Section 290, Subchapter F. Public water systems are required to properly disinfect water before distribution, maintain acceptable disinfection residuals within the distribution system, monitor the disinfectant residual at various locations throughout the distribution system and report the results of that monitoring to the TCEQ on a quarterly basis.

Results of regular monitoring are an indicator of whether or not your drinking water is safe from microbial contamination.

This violation occurred in the monitoring period First Quarter 01/01/2019 – 03/31/2019.

We have taken the following actions to address this issue:

Disinfectant Level Quarterly report (DLQOR) for the First Quarter of 2019 as well as all subsequent DLQOR reports have been filed and remain current.

Please share this information with all people who drink this water, especially those who may not have received this notice directly (i.e., people in apartments, nursing homes, schools and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

If you have questions regarding this matter, you may contact Timothy Barnes at 903-786-7000.

Posted/Delivered on: September 5, 2019